



CERTIFICATE OF QUALIFICATION

Certify that the facilities:

**Clean Area:
Clean Room 5 and Clean Room 6**

Belonging to the enterprise:

Inden Pharma Packaging, S.L.
Pol. Ind. Alfaç III. C/ Ávila, 6. 03440 Ibi (Alicante)

They have been qualified by TELSTAR TECHNOLOGIES, S.L.U.
Customer Services Division, according to the requirements specified
by INDEN PHARMA PACKAGING, S.L.

**Filling all the specified requirements and achieving a
classification ISO 7 (ISO 14644-1)**

Systemair DW-120-BK Serial number 2841776-1
Termoven CL-0001-100S Serial number UTA-2
Systemair NB 29 Serial number 6-26338-2011-2089363
Tecnivel THF-605/351-AE Serial number CC-006-T-15

With a correct result in the integrity test done

Qualification date: 23th of January of 2021
Report No: 4072592

11th of March of 2021

Issued by: Telstar Customer Services. AZBILTELSTAR TECHNOLOGIES, S.L.U.



CERTIFICATE OF QUALIFICATION

Certify that the facilities:

Clean Area:

**Clean Room 1, SAS´ s wardrobe 1, SAS´ s Materials 1,
Clean Room 2, SAS´ s wardrobe 2, SAS´ s Materials 2
Clean Room 3, SAS´ s wardrobe 3, SAS´ s Materials 3,
Clean Room 4, SAS´ s Materials 4, SAS´ s wardrobe 5
and SAS´ s Materials 5-6**

Belonging to the enterprise:

Inden Pharma Packaging, S.L.

Pol. Ind. Alfaç III. C/ Ávila, 6. 03440 Ibi (Alicante)

They have been qualified by TELSTAR TECHNOLOGIES, S.L.U.
Customer Services Division, according to the requirements specified
by INDEN PHARMA PACKAGING, S.L.

**Filling all the specified requirements and achieving a
classification ISO 8 (ISO 14644-1)**

Qualification date: 23th of January of 2021
Report No: 4072592

11th of March of 2021

Issued by: Telstar Customer Services. AZBIL TELSTAR TECHNOLOGIES, S.L.U.

This certification is conditioned upon the company maintains facilities in accordance with established standards